

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1063

Dated: 6-6-2025

It is certified that an inspection team headed by ... Harmanpreet Singh (S.D.E.)

(Name of Officers with designation) from ... SUB, DIVISION, No. 2, ROOPNAGAR, PHED

inspected the ... Holy Angels Convent School, Bharatgarh.

(Name & Address of the school) on ... 26/6/25 ... (date of inspection) and on the basis of

Water Test Report (Attached) bearing no ... RAWTL/2526/00194 ... dated ... 29/05/2025

of RAWTL, MOHALI ... (PHED Lab) certified that

the ... Holy Angels Convent School ... (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ... 5/6/2026 ...

Signature with Seal: ...

Name

Designation

Name & Address of the Office / Department : DWS

: Harmanpreet Singh

: S.D.E. Sub. Division no. 2, Roopnagar

To
Holy Angels Convent School
Kabarala, Bharatgarh, Roopnagar
(Name & Address of the Institution)

Sub Divisional Engineer
Water Supply & Sanitation
Sub Division No. 2, Roopnagar

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT WATER TESTING LABORATORY, ROOPNAGAR

Department of Water Supply and Sanitation, Division -2 , Roopnagar
dwtlrpr@gmail.com

To,

Holy Angel's Convent School, Roopnagar
Holy Angel's Convent School, Bharatgarh, Roopnagar

No.: DWTLRPR/2425/00350 Dated : 27/02/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Letter No. SPL-01 Dated: 17/02/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 17/02/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Roopnagar

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Roopnagar

DISTRICT WATER TESTING LABORATORY, ROOPNAGAR

Department of Water Supply and Sanitation, Division -2 , Roopnagar
dwtlrpr@gmail.com

TEST REPORT						
Name & Address of Customer : Holy Angel's Convent School, Roopnagar Holy Angel's Convent School, Bharatgarh, Roopnagar			Customer Reference No.		No : Letter No. SPL-01 Dated : 17/02/2025	
			Sample Submitted by			
			Date of Sample Receipt		17/02/2025	
			Analysis Starting Date		21/02/2025	
			Analysis completion Date		25/02/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC98822500000033F		Sample Type :		Water	
Test Report No.:	DWTLRPR/2425/00350		Date of Issue :		27/02/2025	
Registration no.:	DWTLRPR/REG2425/00868		Condition of Sample :		Unsealed	
Collection Point:	Distribution Point(Near Bus stand,School,Gurudwara,etc)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		Holy Angel's Convent School, Bharatgarh, Roopnagar (Borewell) / NA	
Village :	Not Mentioned		Habitation :		Not Mentioned	
Block:	Not Mentioned		District :		Roopnagar	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.31@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	375	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.79	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	220	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	348	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	109.02	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	18.47	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	18	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Praveen Singh Danu
Chemist/Analyst
Authorized Signatory
For, District Water Testing Laboratory
Roopnagar

----- End of the Test Report -----

REGIONAL ADVANCE WATER TESTING LABORATORY, PHASE 2- SAS

NAGAR

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab
rawtlmohali@gmail.com

To,

Principal,
Holy Angels Convent School Kakrala, Distt. Roopnagar.

No.: RAWTL/2526/00194 Dated : 29/05/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 05 Dated: 26/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 26/05/2025. It is request to fill the attached feedback form and send it back to Regional Advance Water Testing Laboratory, Phase 2- SAS Nagar

D/A : Test Report



Authorized Signatory
For, Regional Advance Water Testing
Laboratory
Phase 2- SAS Nagar

REGIONAL ADVANCE WATER TESTING LABORATORY, PHASE 2- SAS NAGAR

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab
rawtlmohali@gmail.com



TC-13027

TEST REPORT						
Name & Address of Customer : Principal, Holy Angels Convent School Kakrala, Distt. Roopnagar.			Customer Reference No.		No : 05 Dated : 26/05/2025	
			Sample Submitted by		Mr. Ravinder Kumar	
			Date of Sample Receipt		26/05/2025	
			Analysis Starting Date		28/05/2025	
			Analysis completion Date		29/05/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC13027250000484F		Sample Type :		Water	
Test Report No.:	RAWTL/2526/00194		Date of Issue :		29/05/2025	
Registration no.:	RAWTL/REG2526/00946		Condition of Sample :		Unsealed	
Collection Point:	NA		Quantity/Type of Bottle:		1000 ml / Transparent Glass Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		Private Borewell, (Holy Angels Convent School Kakrala, Distt. Roopnagar) / NA	
Village :	Not Mentioned		Habitation :		Not Mentioned	
Block:	Roopnagar		District :		Roopnagar	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	BDL(0.010)	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	BDL(0.001)	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron(Fe)	BDL(0.005)	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper(Cu)	BDL(0.010)	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	BDL(5)	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
12	Manganese(Mn)	BDL(0.005)	0.1	0.3	mg/l	APHA (24th Ed. 2023) Method :3125 B By ICPMS
13	Zinc(Zn)	BDL(0.01)	5	15	mg/l	APHA (24th Ed. 2023) Method: 3125 B By ICPMS

Continue on next page...

Reviewed and Approved By

Mr. Satyender Singh
Sr. Chemist
Authorized Signatory
For, Regional Advance Water Testing Laboratory
Phase 2- SAS Nagar

REGIONAL ADVANCE WATER TESTING LABORATORY, PHASE 2- SAS NAGAR

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab
rawtlmohali@gmail.com



TC-13027

14	Barium	0.336	0.7	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
----	--------	-------	-----	---------------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By

Mr. Satyender Singh
Sr. Chemist
Authorized Signatory
For, Regional Advance Water Testing Laboratory
Phase 2- SAS Nagar

----- End of the Test Report -----